

Testing tools

VT DIGI PRO

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16

D-32758 Detmold

Germany

Fon: +49 5231 14-0

Fax: +49 5231 14-292083

www.weidmueller.com



The main function of the voltage tester is to establish if voltage is present. A 2-pole voltage tester is the only approved testing instrument that fulfils the requirements of work protection regulations.

- with LCD-Display
- acc. to VDE standard,
- high peak voltage strength
- the right tester for every application

General ordering data

Type	VT DIGI PRO
Order No.	9918870000
Version	2-pole voltage tester type 1152
GTIN (EAN)	4032248405756
Qty.	1 pc(s).

Testing tools VT DIGI PRO

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Technical data

Dimensions and weights

Width	264 mm	Width (inches)	10.394 inch
Height	33 mm	Height (inches)	1.299 inch
Depth	67 mm	Depth (inches)	2.638 inch
Weight	295 g	Net weight	444 g

Environmental Product Compliance

REACH SVHC Lead 7439-92-1

Measuring and testing devices

AC voltage display	1 - 1,000 V	AC voltage measuring range	1 - 1,000 V
Accessories description	Screw-on, thicker test probes	Battery type	1.5 V type AAA battery
Continuity test	Yes - visual + acoustic	DC voltage display	1 - 1,000 V
DC voltage measuring range	1000 V	Display	LCD digital
Frequency measurement	Yes	Frequency range, max.	400 Hz
Frequency range, min.	16 Hz	Input resistance, voltage	On operating the double switch $\geq 300 \text{ k}\Omega$
Insulation test	8 kV	Measuring range category	CAT III 1.000V / CAT IV 600V
Operating temperature, max.	55 °C	Operating temperature, min.	-15 °C
Peak voltage resistance	8 kV	Protection degree	IP65
RCD circuit breaker	The selectable load enables conscious triggering of a 30 mA RCD circuit breaker	Rated voltage, max.	1000 V AC/DC
Rated voltage, min.	1 V	Tested and approved according to	IEC 61243-3:2014 (DIN EN 61243-3:2015-08)

Classifications

ETIM 3.0	EC000494	ETIM 4.0	EC000494
ETIM 5.0	EC000494	ETIM 6.0	EC000494
UNSPSC	41-11-36-37	eClass 5.1	27-20-03-08
eClass 6.2	27-20-03-08	eClass 7.1	27-20-03-08
eClass 8.1	27-20-03-08	eClass 9.0	27-20-03-08
eClass 9.1	27-20-03-08		

Product information

Descriptive text ordering data	Protective case included
Descriptive text technical data	Buzzer included

Approvals

Approvals



ROHS Conform

Data sheet**Testing tools
VT DIGI PRO**

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 16
D-32758 Detmold
Germany
Fon: +49 5231 14-0
Fax: +49 5231 14-292083
www.weidmueller.com

Technical data**Downloads**

Approval/Certificate/Document of Conformity	9918870000_DECLARATION_OF_CONFORMITY.pdf
Brochure/Catalogue	CAT 6 TOOLS 15/16 EN
Product Change Notification	PCN-PW641010-20180410-00-A DE PCN-PW641010-20180410-00-A EN
User Documentation	BANL_manual 2pol Tester
